

FIRE ALARMS - ACADEMIC BUILDINGS

(Page 1)

- ADMIN. BLDG: Does not reset itself. Panel is in the Transformer Cage in the equipment Room. Large bell in Post Office is hooked to flow switch on sprinkler system. Silence the panel, reset the station, reset the panel.
- ATWOOD: Does not reset itself. The panel is in room A04. Silence the panel, reset the station, and reset the panel.
- BROWN HALL: Does not reset itself. The panel is in basement electrical room. Silence the alarm, reset the station, and reset the panel.
- BUSINESS BLDG: Panel is in the main entry on 1st floor in the connecting link to the addition. Does not reset itself. Silence and reset at the panel.
- CENTENNIAL: Has an old and new panel. New panel is located by 1st floor west entry and it's zones cover the Bookstore and basement south water flow and dry system located in room #31. if dry system is cause of alarm, MAINTENANCE MUST BE CALLED. old panel is located in basement center mechanical room, and cover the remainder of building. (heats & pulls) each panel will alarm the other panel. For reset procedure refer to instructions by old panel.
- EASTMAN HALL: Does not reset itself. The panel is at the bottom of the basement stairs. Acknowledge the alarm, solve the problem, reset the panel.
- E.C.C.: Does not reset itself. Main panel in the main electrical room near the Bee Hive. Silence the alarm, reset the station, and reset the panel.
- EDUCATION BLDG.: Does not reset itself. The panel is in the basement electrical room. Silence the alarm, reset the station, and reset the panel.
- HUSKY STADIUM, HALENBECK NORTH & HALENBECK SOUTH:
Does not reset itself, panel located in Stadium RM #150-8. Push alarm acknowledge button. Read LED display to learn location of problem. Verify problem, silence only if there is no threat to life or property. Fix problem then reset panel. If the dry system is the cause of alarm MAINTENANCE MUST BE CALLED.
- HEADLEY HALL: Does not reset itself. The panel is in the basement equip. room. Silence the alarm, reset the station, and reset the panel.

FIRE ALARMS - ACADEMIC BUILDINGS

(Page 2)

HEATING PLANT:

Does not reset itself. The panel is located in the appliance repair shop in the main east-west hallway. Acknowledge the alarm, reset the station, and reset the panel.

KIEHLE:

Does not reset itself. The panel is in the basement equip. room. Silence the alarm, reset the station, and reset the panel.

MAINT. BLDG

The panel is located in the electrical room inside of the warehouse. Must have a maintenance supervisor open the warehouse. Does not reset itself. First silence the panel by moving the switch on the 2nd card from the left from normal to disc. Solve the problem. Put switch back to normal. Reset the panel.

MATH-SCIENCE:

Does not reset itself, but will stop when station is returned to normal. The panel is in the basement equip. room. The meter on the panel will indicate a problem if the needle does not line up with the mark. After problem is solved, reset bi-metal strip inside of the panel. The system is reset if no alarm resounds. If the problem is not found and corrected, the main building is without a fire alarm system. The greenhouse has its own panel next to the main building panel. For it, silence the alarm, reset the station, reset the panel.

MILLER CENTER:

Panel does not reset itself. Panel is located in Main North entry. Push alarm acknowledge button. Read LED display to learn location of problem. Verify problem, silence only if there is no threat to life or property. Fix problem then reset panel.

NHC:

Does not reset itself. The panel is in the manager's office, room 12. Push alarm acknowledge button. Read LED display to learn location of problem. Verify problem, silence only if there is no threat to life or property. Fix problem then reset panel.

PERFORMING ARTS:

Does not reset itself. The panel is in the electrical room in the sub-basement. Silence the panel, reset the station, and reset the panel.

(09/09/05)

FIRE ALARMS - ACADEMIC BUILDINGS

(Page 3)

RIVERVIEW:

Does not reset itself. The panel is in the tunnel to Eastman. Silence the system, reset the station, and reset the panel.

STEWART:

Panel does not reset itself. The panel is in room 7. Push alarm acknowledge button. Read LED display to learn location of problem. Verify problem, silence only if there is no threat to life or property. Fix problem then reset panel.

WHITNEY HOUSE:

Alarm will time out. Problem must be found. After problem is solved, reset bi-metal strip inside of the panel. The system is reset if no alarm resounds. If the problem is not found and corrected, the whole building is without a fire alarm system. The panel is in the room south of the basement equipment room.